

Furnace Air Intake To Be Heated

tdb = 70 F

RH = 35 %

W = 0.0054077 lb w.v./lb d.a.

ACFM = 1250

SCFM = 1244.0472

Dry Air = 5568.1017 lb d.a./hr

Water Vapor = 30.1109 lb d.a./hr

Total = 5598.2126 lb/hr

 $Q_{\text{sensible}} = 50,759.21 \text{ Btu/hr}$ $Q_{\text{latent}} = 32,891.05 \text{ Btu/hr}$ $Q_{\text{total}} = 83,650.26 \text{ Btu/hr}$ **Heated Air Leaving The Furnace**

tdb = 138.3641 F

RH = 4.5752 %

W = 0.0054077 lb w.v./lb d.a.


ACFM = 1411.3365

SCFM = 1244.0472

Dry Air = 5568.1017 lb d.a./hr

Water Vapor = 30.1109 lb w.v./hr

Total = 5598.2126 lb/hr

 $Q_{\text{sensible}} = 142,189.24 \text{ Btu/hr}$ $Q_{\text{latent}} = 33,763.81 \text{ Btu/hr}$ $Q_{\text{total}} = 175,953.05 \text{ Btu/hr}$ **Combustion Air Intake**

tdb = 40 F

RH = 40 %

W = 0.00205497 lb w.v./lb d.a.

ACFM = 16.7460

SCFM = 17.7026

Dry Air = 79.4983 lb d.a./hr

Water Vapor = 0.1634 lb w.v./hr

Total = 79.6617 lb/hr

 $Q_{\text{sensible}} = 152.80 \text{ Btu/hr}$ $Q_{\text{latent}} = 176.32 \text{ Btu/hr}$ $Q_{\text{total}} = 329.12 \text{ Btu/hr}$

10 % Excess Air

Flue Gas Discharge

tdb = 119.1960 F

W = 0.1296687 lb w.v./lb dry gas

CO₂ = 11.7888 lb/hrN₂ = 61.0971 lb/hrO₂ = 1.6725 lb/hrSO₂ = 0.0001 lb/hrSO₃ = 0.0000 lb/hr

Argon = 0.0934 lb/hr

Dry Gas = 74.6518 lb/hr

Water Vapor = 5.8709 lb/hr

Wet Flue Gas = 80.5227 lb/hr

Acid Dew Point Temperature = 178.9587 F

Dry Gas Heat = 1,569.24 Btu/hr

Water Vapor Heat = 6,457.08 Btu/hr

Total Heat = 8,026.32 Btu/hr